



NOTES:

1. SIDEWALKS SHALL BE A MINIMUM OF 5' WIDE AND 4" THICK, EXCEPT AT DRIVEWAYS WHERE THICKNESS SHALL BE 6".
2. ALL UTILITIES SHALL HAVE MARKER TAPE OR OTHER APPROVED MEANS OF IDENTIFICATION. REFER TO APPROPRIATE SECTION OF "CITY OF GROVELAND MANUAL OF STANDARDS FOR DESIGN, CONSTRUCTION AND MAINTENANCE OF WATER AND SEWAGE SYSTEMS".
3. REFER TO APPROPRIATE SECTION OF "CITY OF GROVELAND MANUAL OF STANDARDS FOR DESIGN, CONSTRUCTION AND MAINTENANCE OF WATER AND SEWAGE SYSTEMS", FOR SEWER AND WATER TRENCHING AND RESTORATION DETAILS, AND ELSEWHERE IN THESE DETAILS FOR OTHER UTILITIES TRENCHING AND RESTORATION.
4. FIRE HYDRANTS SHALL BE INSTALLED TO MINIMIZE THEIR VULNERABILITY TO TRAFFIC.

CITY OF GROVELAND STANDARD DETAILS: STREET & DRAINAGE



METZGER & WILLARD, INC.
 Civil • Environmental Engineers • Surveyors
 8600 Hidden River Parkway, Suite 550
 Tampa, Florida 33637 (813) 977-6005

RECOMMENDED UTILITIES LOCATIONS

DATE: JULY 7, 2008
 SCALE: N.T.S.

D-1