



NOTES:

1. SIDEWALKS SHALL BE 4" THICK EXCEPT AT DRIVEWAYS WHERE THICKNESS SHALL BE 6".
2. SIDEWALK WIDTH SHALL BE 5 FEET UNLESS OTHERWISE DIRECTED BY CITY OF GROVELAND.
3. APRON WIDTH AT STREET SHALL BE A MINIMUM OF 2 FEET GREATER THAN DRIVEWAY WIDTH.
4. SIDEWALKS TO MATCH DRIVEWAY ELEVATIONS.

**CITY OF GROVELAND STANDARD DETAILS: STREET & DRAINAGE**



**METZGER & WILLARD, INC.**  
 Civil • Environmental Engineers • Surveyors  
 8600 Hidden River Parkway, Suite 550  
 Tampa, Florida 33637 (813) 977-6005

**RESIDENTIAL SIDEWALK  
& DRIVEWAY**

DATE: JULY 7, 2008  
 SCALE: N.T.S.

**D-4**