



NOTES:

1. CURB INLET TOPS SHALL BE FDOT TYPE 5 OR TYPE 6. (TYPE 6 SHOWN). FRAME AND COVER SHALL BE STEEL MEETING ASTM A-36 OR CAST IRON, CLASS No. 30 IN ACCORDANCE WITH ASTM A-48.
2. PRECAST STRUCTURES SHALL BE FDOT TYPE P OR J AND MAY BE CIRCULAR, SQUARE OR RECTANGULAR, WALL THICKNESS AND REINFORCEMENT SHALL BE IN ACCORDANCE WITH ASTM C-478.
3. MINIMUM INSIDE DIMENSIONS SHALL BE 4' DIAMETER FOR CIRCULAR AND 3'-6" FOR SQUARE OR RECTANGULAR.
4. ALTERNATE DRAINAGE INLET DESIGNS MAY BE PROPOSED BY ENGINEER.

CITY OF GROVELAND STANDARD DETAILS: STREET & DRAINAGE



METZGER & WILLARD, INC.
 Civil • Environmental Engineers • Surveyors
 8600 Hidden River Parkway, Suite 550
 Tampa, Florida 33637 (813) 977-6005

CURB DRAINAGE INLET

DATE: JULY 7, 2008
 SCALE: N.T.S.

D-7