



NOTES:

$D_1 = 5'$ STD. (SINGLE PANEL FOR DEPTHS 5' OR LESS).

$D_2 = 5'$ STD. (ADDITIONAL PANEL FOR DEPTHS > 5')

CURTAIN TO REACH BOTTOM UP TO DEPTHS OF 10 FEET. TWO (2) PANELS TO BE USED FOR DEPTHS GREATER THAN 10 FEET UNLESS OTHERWISE SPECIFIED IN THE CONSTRUCTION PLANS OR AS DIRECTED BY THE ENGINEER

CITY OF GROVELAND STANDARD DETAILS: GENERAL



TYPE I FLOATING TURBIDITY
BARRIER

DATE: JULY 7, 2008
SCALE: N.T.S.

G-3