



NOTES:

1. DEWATERING SHALL CONTINUE UNTIL BACKFILL IS COMPACTED AT LEAST 2 FEET ABOVE WATER TABLE.
2. SURFACE TREATED PAVEMENT JOINTS SHALL BE LAPPED AND FEATHERED.
3. EMBEDMENT TYPE 3 PER AWWA C600/C605. PIPE BEDDED IN SAND TO DEPTH OF $\frac{1}{8}$ PIPE DIAMETER, 4 INCHES MINIMUM. BACKFILL COMPACTED TO TOP OF PIPE. BACKFILL SHALL BE COMPACTED IN ONE FOOT LIFTS WITH MECHANICAL TAMPERS AND UP TO THE BOTTOM OF THE ROADWAY BASE. SPECIAL ATTENTION SHALL BE GIVEN TO ADEQUATE COMPACTION OF THE PIPE HAUNCHES. A DENSITY TEST IS REQUIRED AT THE SPRING LINE, ONE FOOT ABOVE THE PIPE CROWN AND ONE FOOT VERTICALLY THEREAFTER.
4. IN PAVEMENT CUT, PROVIDE 2 INCHES OF TYPE SIII ASPHALT; THEN, 1 INCH OF TYPE SI OVERLAY OR MATCH EXISTING IF GREATER, 50 FEET LONG CENTERED ON CUT.

**TRENCH REPAIR—PAVED AREAS
AND PAVEMENT REPLACEMENT**

CITY OF GROVELAND STANDARD DETAILS: GENERAL



METZGER & WILLARD, INC.
Civil • Environmental Engineers • Surveyors
8600 Hidden River Parkway, Suite 550
Tampa, Florida 33637 (813) 977-6005

**OPEN CUT AND REPAIR
DETAIL**

DATE: JULY 7, 2008
SCALE: N.T.S.

G-6