



NOTES:

1. NEW OR RELOCATED, UNDERGROUND WATER MAINS CROSSING ANY EXISTING OR PROPOSED GRAVITY OR VACUUM SANITARY SEWER OR STORMSEWER SHALL BE LAID SO THE OUTSIDE OF THE MAIN IS AT LEAST SIX INCHES, ABOVE OR AT LEAST TWELVE INCHES, BELOW THE OUTSIDE OF THE OTHER PIPELINE. HOWEVER, IT IS PREFERABLE TO LAY THE WATER MAIN ABOVE THE OTHER PIPELINE.
2. NEW OR RELOCATED, UNDERGROUND WATER MAINS, CROSSING ANY EXISTING OR PROPOSED PRESSURE SANITARY SEWER, WASTEWATER OR STORMWATER FORCE MAIN, OR RECLAIMED WATER MAIN SHALL BE LAID SO THE OUTSIDE OF THE WATER MAIN IS AT LEAST TWELVE INCHES ABOVE OR BELOW THE OUTSIDE OF THE OTHER PIPELINE. HOWEVER, IT IS PREFERABLE TO LAY THE WATER MAIN ABOVE THE OTHER PIPELINE.

CITY OF GROVELAND STANDARD DETAILS: GENERAL



METZGER & WILLARD, INC.
Civil • Environmental Engineers • Surveyors
 8600 Hidden River Parkway, Suite 550
 Tampa, Florida 33637 (813) 977-6005

**ADJUSTMENTS TO CLEAR
 EXISTING UTILITIES**

DATE: JULY 7, 2008
 SCALE: N.T.S.

G-12