



**FOR EITHER PAVED OR NON-PAVED AREAS**

**NOTES:**

1. MECHANICAL JOINTS/UNDERGROUND PIPING SHALL BE RESTRAINED AS SPECIFIED IN JOINT RESTRAINT TABLE.
2. OPERATING NUT SHALL BE WITHIN 12" OF GRADE. EXTENSION TO BE PROVIDED AS REQUIRED.
3. VALVE EXTENSION SHALL BE MECHANICALLY ATTACHED AND SHALL HAVE A STAINLESS STEEL PIN AT THE VALVE AND SHEAR PIN ONLY AT THE OPERATING NUT.

**CITY OF GROVELAND STANDARD DETAILS: RECLAIMED WATER**



**METZGER & WILLARD, INC.**  
*Civil • Environmental Engineers • Surveyors*  
 8600 Hidden River Parkway, Suite 550  
 Tampa, Florida 33637 (813) 977-6005

**PERMANENT BLOW-OFF  
 DETAIL**

DATE: JULY 7, 2008  
 SCALE: N.T.S.

**R-6**