

MINIMUM LENGTH OF PIPE (IN FEET) REQUIRED TO  
BE RESTRAINED ON EACH SIDE OF A VALVE OR  
FITTING FOR SANDY SOILS (SW, SP, SM, SC)

PIPE TYPE	PIPE SIZE	90° BEND	45° BEND	≤22.5° BEND	TEE OR CROSS	VERTICAL OFFSET <sup>a</sup>		REDUCER <sup>b</sup>	VALVE	DEAD END
						LOW	HIGH			
P V C  P I P E	≤4	18	18	18	18	18	22	36	18	52
	6	24	18	18	18	18	30	38	36	73
	8	31	18	18	18	18	40	69	36	96
	10	37	18	18	18	18	48	93	54	115
	12	43	18	18	18	18	56	99	54	136
	14	49	20	18	18	18	64	101	72	155
	16	55	23	18	18	18	72	103	72	174
	18	60	25	18	36	20	80	104	72	192
	20	65	27	18	36	21	87	105	72	211
	24	75	31	18	36	25	102	134	90	246
	30	88	37	18	36	29	122	185	90	295

PIPE TYPE	PIPE SIZE	90° BEND	45° BEND	≤22.5° BEND	TEE OR CROSS	VERTICAL OFFSET <sup>a</sup>		REDUCER <sup>b</sup>	VALVE	DEAD END
						LOW	HIGH			
D U C T I L E  I R O N	≤4	18	18	18	18	18	18	18	18	33
	6	20	18	18	18	18	19	35	36	47
	8	26	18	18	18	18	25	44	36	61
	10	31	18	18	18	18	30	60	54	73
	12	37	18	18	18	18	36	63	54	86
	14	41	18	18	18	18	41	64	72	98
	16	46	19	18	36	18	46	66	72	111
	18	51	21	18	36	18	51	66	72	122
	20	56	23	18	36	18	56	67	72	134
	24	64	27	18	36	21	65	85	90	156
	30	75	31	18	36	25	78	118	90	188

**CITY OF GROVELAND STANDARD DETAILS: RECLAIMED WATER**



**METZGER & WILLARD, INC.**  
Civil • Environmental Engineers • Surveyors  
8600 Hidden River Parkway, Suite 550  
Tampa, Florida 33637 (813) 977-6005

**PIPE RESTRAINT  
SCHEDULE**

DATE: JULY 7, 2008  
SCALE: N.T.S.

**R-12A**