



NOTES:

1. ADJUST VERTICAL ALIGNMENT OF PROPOSED FORCE MAIN SO THAT HIGH POINT IS MINIMUM 3' BELOW FINISHED GRADE.
2. WITHIN PAVEMENT AND SHOULDER AREAS, FRAME AND COVER SHALL BE TRAFFIC BEARING.

CITY OF GROVELAND STANDARD DETAILS: SANITARY SEWER



METZGER & WILLARD, INC.
Civil • Environmental Engineers • Surveyors
8600 Hidden River Parkway, Suite 550
Tampa, Florida 33637 (813) 977-6005

**SEWAGE AIR RELEASE
VALVE ASSEMBLY WITH
BOX AND COVER**

DATE: JULY 7, 2008
SCALE: N.T.S.

S-6