



**NOTES:**

1. ADJUST VERTICAL ALIGNMENT OF PROPOSED FORCE MAIN SO THAT HIGH POINT IS MINIMUM 3' BELOW FINISHED GRADE.
2. WITHIN PAVEMENT AND SHOULDER AREAS, FRAME AND COVER SHALL BE TRAFFIC BEARING.

**CITY OF GROVELAND STANDARD DETAILS: SANITARY SEWER**



**METZGER & WILLARD, INC.**  
*Civil • Environmental Engineers • Surveyors*  
 8600 Hidden River Parkway, Suite 550  
 Tampa, Florida 33637 (813) 977-6005

**SEWAGE AIR RELEASE  
 VALVE ASSEMBLY-OFFSET**

DATE: JULY 7, 2008  
 SCALE: N.T.S.

**S-7**