



NOTES:

1. ELECTRICAL EQUIPMENT TO BE ACCESSIBLE WITH A MINIMUM OF 5 FEET CLEARANCE.
2. ALL CABLES TO PANELS AND CABINETS SHALL BE INSTALLED IN RIGID CONDUITS, MINIMUM 2" DIAMETER. ABOVE GRADE CONDUITS SHALL BE GALVANIZED. BELOW GRADE CONDUITS SHALL BE PVC.
3. AT LEAST TWO SEALS SHALL BE PROVIDED FOR CABLES IN CONDUITS. FOR ENTRY POINTS AT PANELS AND CABINETS, SEALS SHALL BE CROUSE-HINDS CHICO O/E EYS TYPE. AT JUNCTION BOXES AND WETWELLS, SEALS SHALL BE ELECTRIC PUTTY.

**CITY OF GROVELAND STANDARD DETAILS: SANITARY SEWER**



**METZGER & WILLARD, INC.**  
 Civil • Environmental Engineers • Surveyors  
 8600 Hidden River Parkway, Suite 550  
 Tampa, Florida 33637 (813) 977-6005

**LIFT STATION ELECTRICAL SCHEMATIC**

DATE: JULY 7, 2008  
 SCALE: N.T.S.

**S-10**