



NOTES:

1. FENCED AREA SHALL BE LAID WITH A MINIMUM OF 6" OF 3/4" WASHED ROCK.
2. INFLUENT AND EFFLUENT MAINS SHALL BE CLEAR OF PANEL.
3. PLAN MAY VARY BASED UPON SPECIFIC SITE REQUIREMENTS UPON APPROVAL FROM CITY

CITY OF GROVELAND STANDARD DETAILS: SANITARY SEWER



METZGER & WILLARD, INC.
 Civil • Environmental Engineers • Surveyors
 8600 Hidden River Parkway, Suite 550
 Tampa, Florida 33637 (813) 977-6005

LIFT STATION SITE PLAN

DATE: JULY 7, 2008
 SCALE: N.T.S.

S-12